



集团微信订阅号



集团微信服务号

测试报告

No. BTQ785TB5973305Z5

样品名称

塑胶面层跑道

工程名称

园南小学 2025 年场地修缮工程

委托单位

上海市徐汇区园南小学

签发日期

2025 年 08 月 14 日



查询密码: Clpc1

声明 Statement

- 1.本报告无检验检测专用章、报告骑缝章和批准人签章无效。
This report is invalid without special seal for inspection and test, cross-page seal and signature of the approver.
- 2.本报告页面所使用“PONY”、“谱尼”字样为谱尼测试集团的注册商标，其受《中华人民共和国商标法》保护，任何未经本单位授权的擅自使用和仿冒、伪造、变造“PONY”、“谱尼”商标均为违法侵权行为，本单位将依法追究其法律责任。
The words "PONY" and "谱尼" used in this report page are the registered trademarks of Pony Testing International Group, which are protected by the Trademark Law of the People's Republic of China. Any unauthorized use, counterfeiting, forging or altering of the trademarks of "PONY" and "谱尼" without the authorization of us is an illegal infringement, and we will investigate their legal liabilities according to law.
- 3.委托单位对报告数据如有异议，请于报告完成之日起十五日内(初级农产品报告请于报告收到之日起五个工作日内)向本单位书面提出复测申请，同时附上报告原件并预付复测费。
If the applicant has any objection to the report data, please submit a written application for retesting to us within 15 days after the completion of the report (for the report of primary agricultural products, submit a written application for retesting to the unit within 5 working days after the receipt of the report), with the original report attached and the retesting fee prepaid.
- 4.委托单位办理完毕以上手续后，本单位会尽快安排复测。如果复测结果与异议内容相符，本单位将退还委托单位的复测费。
After the applicant completes the above procedures, we shall arrange the retesting as soon as possible. If the retest result is consistent with the objection, we will refund the retest fees.
- 5.不可重复性或不能进行复测的实验，不进行复测，委托单位放弃异议权利。
If the experiment cannot be repeated or cannot be retested, no retest shall be conducted, and the applicant shall waive the right of objection.
- 6.委托单位对送检样品的代表性和资料的真实性负责，否则本单位不承担任何相关责任。
The applicant is responsible for the representativeness of the commissioned samples and the authenticity of the documents, otherwise we do not assume any relevant responsibilities.
- 7.本报告未加盖检验检测资质认定标志，委托单位仅用于科研、教学、内部质量控制等活动使用，和/或不在本单位资质认定范围内，仅供内部参考，不具有社会证明作用。本报告仅对所测样品的测试结果负责，对于测试数据的使用、使用所产生的直接或间接损失及一切法律后果，本单位不承担任何经济和法律后果。
This report without CMA is only used for scientific research, teaching, internal quality control by the applicant, and/or not within the scope of ours CMA, for internal reference only, does not have social proof function. This report is only responsible for the test results of the tested sample. We do not assume any economical or legal liability generated from direct or indirect usage of the test report.
- 8.本单位有权在完成报告后按规定方式处理所测样品，除客户特别声明并支付样品管理费，所有超过标准规定时效期的样品均不再做留样。
We have the right to dispose the tested sample after approval of the test report. Unless the applicant specifically declares and pays the sample management fee, all samples beyond the validity period specified in the standard will not be retained.
- 9.本单位保证工作的客观公正性，对委托单位的商业信息、技术文件等商业秘密履行保密义务。
We assure the objectivity and impartiality of the test, and fulfills the obligation of confidentiality for applicant's commercial information, and technique document.
- 10.本报告私自转让、盗用、冒用、涂改、未经本单位批准的复制(全文复制除外)或以其它任何形式的篡改均属无效，本单位将对上述行为追究其相应的法律责任。
Any unauthorized transfer, appropriation, falsification, alteration, copying (except full text copying) or alteration in any other form of this report without the approval of us shall be invalid. We shall strictly investigate the corresponding legal liability for the aforesaid behavior.

▲防伪说明(Anti-counterfeiting Instructions):

- 1.报告编号是唯一的;
The report number is unique.
 - 2.扫描报告首页下方二维码，即可查询报告真伪。
Scan the QR code below the first page to check the authenticity of the report.
- *****

测试报告

No. BTQ785TB5973305Z5


共 3 页 第 1 页

样品名称	塑胶面层跑道		测试类别	见证送样
型号规格/等级	300mm×400mm		商标	——
批号或编号	——		样品数量	4 块
生产日期	——		代表批数量	1500m ²
委托单位名称	上海市徐汇区园南小学			
生产单位名称	——			
工程名称	园南小学 2025 年场地修缮工程	工程地址	平福路园南二村 71 号	
样品见证	上海诚灵建设咨询监理有限公司 李燕（证书编号：30618）	取样部位	场地东南角	
固化时间	16 天	取样日期	2025-08-08	
委托单编号	BTQ785T	送样日期	2025-08-08	
样品编号	B5973305Z5	委托日期	2025-08-08	
样品状态描述	红色成品样块			
参考方法	GB 36246-2018、GB/T 10654-2001、GB/T 14833-2020、TY/T 2003.7-2021、GB/T 30314-2021、GB/T 43564-2023			
测试日期	2025-08-08~2025-08-14			
测试结论	该样品经测试，所测项目符合 T/SHHJ000003-2025《学校绿色合成材料面层运动场地》表 2 要求。 测试机构（盖章） 签发日期：2025 年 08 月 14 日			
委托单位 通讯资料	地址	平福路园南二村 71 号		
	邮编	——	电话	13817964823
备注	1、合成材料面层：田径场地； 2、样品厚度：13mm； 3、面层类型：现浇型、渗水型、非水基型； 4、生产商/供应商：江苏彩虹； 5、区专管员：上海市徐汇区学校事务管理中心-虞硕华。			


批准人姓名：朱云峰

审核人姓名：陈露露

编制人姓名：王秀娟

签字：

签字：

签字：

☎Hotline 400-819-5688

www.ponytest.com

PONY-SHBG056-02B-063-2024A

谱尼测试集团上海有限公司

公司地址：上海市松江区施园路 288 号 1 幢 4 层 A 区

测试地址：上海市松江区施园路 288 号

电话：021-64851999

测试报告

No. BTQ785TB5973305Z5

共 3 页 第 2 页

测 试 结 果 汇 总						
序号	测试项目			标准值	测试结果	单项判定
1	冲击吸收，%	田径场地	(0±2) °C	35~50	36.2	符合
2			(23±2) °C		43.2	
3			(50±2) °C		47.9	
4	垂直变形，mm			0.6~3.0	1.8	符合
5	抗滑值（20℃），BPN		田径场地	≥47（湿测）	66.0	符合
6	拉伸强度，MPa		渗水型面层	≥0.5	0.53	符合
7	拉断伸长率，%			≥50	51.6	符合
8	阻燃性能，级			I	I	符合
9	耐磨性，g			≤3.0	0.240	符合
10	色牢度			干、湿两种条件下均无脱色	无脱色	符合
	(以下空白)					
说明	—————					

测试报告


No. BTQ785TB5973305Z5

共 3 页 第 3 页

样品照片



第 1 面



第 2 面

———本报告内容结束———

